B) The measurement options in 597.3 (a) cannot be met with commercially available measurement technology, either manufactured devices or site-built devices. To demonstrate lack of commercially available technology, the agricultural water supplier shall, for each year that this measurement option is to be exercised, file a report with the Department that --

(i) documents the specific conditions regarding flow, head loss, canal stability, crop selection, on-farm practices, or other factors that preclude accurate measurement with available technology for each customer downstream of the point of measurement, attested by a registered Professional Engineer; and

(ii) a summary of the agricultural water supplier's efforts during the previous twelve months to locate and evaluate commercially available technology that may be suitable for accurate measurement of water deliveries under the conditions identified in clause (i) above.